



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in 🌐 www.riveramarketing.in

Complaint no. 1838

SERVICE REPORT

Report No. 076

Date 28/07/2017

Customer's Name & Address

Manmohan Terry (P) Ltd
Piplaj
Ahmedabad

Ser. Engr's Name :

Jayesh / Ramesh

Machine Model :

2KDH 050B

Serial No. :

13771-12/15

Period of Service :

Contact Person

Mr. Yodhisht

Contact Number

Hours Run :

Nature of Service : ☐ Commissioning ☐ Inspection ☒ Repairs

☐ Product Complaint / Failure

Expansion valve fail

Work Done : we have attended the site check at the machine. The expansion valve is fail, so I have change the expansion valve and fill up to nitrogen pressure to check leakage no any other leakage in the D/L. so I have Recharge the R134a gas. Tested the unit found working good.

Spares Used expansion valve 02 NOS

R134a gas. Nitrogen

Spares Recommended

Customer's Remarks : Your Mr. _____ Called on _____ He attended to the Job from _____ to _____ The Works in completed/not completed satisfactorily.

Service Engr.

Jayesh chavda
9979899534
Signature

Customer

Manmohan Singh
Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.