



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in 🌐 www.riveramarketing.in

Complaint - 1881

SERVICE REPORT

Report No. 084

Date 04/08/2017

Customer's Name & Address Chiripal Industries Ltd. Gandhinagar (Gandhinagar Pipri) Area Narol, Ahmedabad.		Ser. Engr's Name : Jyesh Chavda
		Machine Model : 2KD1050B
		Serial No. : 5451-5126
Contact Person Mr. Vishal Bhatt		Period of Service :
Contact Number		Hours Run :
Nature of Service : ☐ Commissioning ☐ Inspection ☐ Repairs ☐ Product Complaint / Failure		
Work Done : Expansion valve fail I have checked the side check on the machine. The expansion valve is fail. So I have changed the new expansion valve. I have checked nitrogen pressure and checked leakage. I have checked leakage in the dryer. So I have packed the dry gas. Reset the unit found everything good.		
Spares Used Nitrogen, Expansion valve, dry gas		Spares Recommended
Customer's Remarks : Your Mr. _____ Called on _____ He attended to the Job from _____ to _____ The Works in completed/not completed satisfactorily.		
Service Engr. Jyesh Chavda 9979899532		Customer V.M. Patel Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.