



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in ● www.riveramarketing.in

SERVICE REPORT

Report No. 033.

Date 07/10/19.

GST NO : 24AAFFR2824J1Z9

Customer's Name & Address

A2A Engineering L10.
UNIT- C15 (KREBICA)
KREBICA GIDC

Ser. Engr's Name :

Jayshchandra

Machine Model :

2K04 150E

Serial No. :

2193-02/19.

Contact Person M.E. Ketan and Suresh Bhai.

Contact Number

Hours Run :

Nature of Service : ☐ Commissioning ☐ Inspection ☒ Repairs

☐ Product Complaint / Failure

Work Done : HP Tapping and Discharge line vibrating.
I have attended the site check of the machine.
HP setting change from 400 Psi to 450 Psi

Discharge line clamp with packing / now no vibration in line

At present unit running load and setting getting deep point.

Spares Used 1/2 inch clamp with
bolt and nuts 02.

Spares Recommended

NO.

Customer's Remarks : Your Mr. _____ Called on _____ He attended to
the Job from _____ to _____ The Works in completed/not completed satisfactorily.

Service Engr. Jayshchandra

Signature

Customer

Signature & Seal of the firm