



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in ● www.riveramarketing.in

Complaint no. 4670

SERVICE REPORT

Report No. 439

GST NO : 24AAFFR2824J1Z9

Date 6/03/2019

Customer's Name & Address

A.V. Organics LLP

Plot No. 90, Infront of Chemco

Unit-02, Ahmedabad, Maharashtra

Contact Person Mr. Rushi Bakhshi

Contact Number

Ser. Engr's Name :

Jayesh Chavda

Machine Model :

2KD 025B

Serial No. :

9104-10/18

Hours Run :

Nature of Service : ☐ Commissioning ☐ Inspection ☒ Repairs

☐ Product Complaint / Failure

Work Done :

Temp Controller is display is not on. Proper
I have attended the site. Check at the machine.
Controller display is not on. Check voltage is ok. But controller
is not functioning sometime on, and sometime off. So I have open
the all cable connection and re-tied the cable on controller. After
observe 1.30 clock controller is working good.

Voltage

Pressure

RY RB YB
410 407 410

R Y B
3.2 1.9 1.8

Spares Used

Nil

Spares Recommended

Nil

Customer's Remarks : Your Mr. Jayesh Chavda Called on A.V. Organics LLP He attended to

the Job from 10:30 to 2:00 The Works in completed/not completed satisfactorily.

He has solve the electrical Problem. But, Still driver's result
is not Satisfactory. Please send refrigerant technician.

Service Engr. Jayesh Chavda

9914549532

Signature

Customer
Outlet temp is
not Satisfied.

Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.