



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in. 🌐 www.riveramarketing.in

SERVICE REPORT

Report No. 443

GST NO : 24AAFFR2824J1Z9

Date 12/03/2019

Customer's Name & Address

JK Lakshmi Cement Ltd.

Jag Raj Arora,

5000, Bhandarkar

Pin-code 301019

Contact Person Mr. Arvindh Bhai

Contact Number

Ser. Engr's Name :

Jyoti Chaudhary

Machine Model :

24D 0028

Serial No. :

11511-12118

Hours Run :

Nature of Service : ☐ Commissioning ☐ Inspection ☒ Repairs

☐ Product Complaint / Failure

Work Done :

Draw Point not maintained by AIR Dyeht Draw Point High
I have attended the job at the machine. The
Pressure draw point is high with out AIR Pressure. so I have
check to replace to fill up nitrogen Pressure 100 Psi in
Dyeht. observe 12 Hours 10 Psi pressure is drop so second
day 11:00 o'clock to fill up to 200 Psi pressure. But no change
in Pressure But the Suction pipe not is normally 100 Psi
so I have tie the not and change to new charging pipe
Vacuum the system and Recharge the Nitrogen gas
Test the unit found works good.

Note :- After machine gas charged this in under observation as per
nearby at main

Spares Used

Nitrogen gas, Nitrogen,
Leak, charging pipe.

Spares Recommended

NO.

Customer's Remarks : Your Mr. Jyoti Chaudhary Called on 11-03-2019 He attended to
the Job from 11-03-2019 to 12-03-2019 The Works in completed/not completed satisfactorily.

Service Engr.

Jyoti Chaudhary

9939899532


Signature

Customer

Rajesh Kumar

Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.