



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in 🌐 www.riveramarketing.in

SERVICE REPORT

Report No. 395

GST NO : 24AAFFR2824J1Z9

Date 27/12/18**Customer's Name & Address**

Kumda Cotton Mills Pvt. Ltd.
Nizaoi Ahmedabad.

Ser. Engr's Name :

Jyesh Chavda

Machine Model :

3G-X 150

Serial No. :

7981-08/26

Hours Run :Contact Person Mr. Pankaj Bhatt

Contact Number

Nature of Service : ☐ Commissioning ☐ Inspection ☐ Repairs

☐ Product Complaint / Failure

Deer point high / fan motor rail and contactor A/B

Work Done : I have the site check at the machine. The deer point is high and MCB was tripping. I have checked fan is failure and fan motor is A/B in order so fan motor is failure. So I have replace and change to fan motor and fan contactor.

→ Test the unit found work good.

Spares Used fan motor of nos

Spares Recommended

fan contactor of nos (Siemens)
3TF30-10-0A

NO

Customer's Remarks : Your Mr. 1 Called on He attended to the Job from to The Works in completed/not completed satisfactorily.


Service Engr. Jyesh Chavda0979899507

Signature

Customer

Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.