

RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h: St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
✉ sales@riveramarketing.in 🌐 www.riveramarketing.in

SERVICE REPORT

Report No. 01-19

Date 05-01-2019

T NO : 24AAFFR2824J1Z9

Customer's Name & Address

L.B. Text Pvt. Ltd.

Keshava GIDC, Ambli-

Rajkot Highway, Guj

Ser. Engr's Name :

Dhaval
Ramesh

Machine Model :

2KD+250E

Serial No. :

7541-07/17

Hours Run :

Contact Person

Kirti Umashankar

Contact Number

7573931141

Nature of Service : ☐ Commissioning

☐ Inspection

☒ Repairs

Product Complaint / Failure

Work Done :

We have visit the site check the Dryer and found
Ex. Valve Failure. Then Remove the R-407 Gas and install New
Exp Valve and charge N2 Pressure 300 PSI No any Leakage
found Then Remove the N2 Pressure and Vacuum the Dryer
System and Charge R-407 Gas in Dryer system. Dryer Purge
Dryer Dew Point - 2 to 3' on full load.

Amperage - R 24.5 Y 24.3 B 23.00

Voltage - RV 410 YB 413 RB 414

Spares Used

EXP. Valve

R-407 - 15KG

Spares Recommended

Customer's Remarks : Your Mr. _____

Called on _____ He attended to

The Job from _____ to _____ The Works in completed/not completed satisfactorily.

Service Engr.



Signature

Customer


Signature & Seal of the firm