

Minutes of Meeting Between M/S Amaze air engineers and M/S SHRI Ram Rice Mills

Sub: Air Dryer Issues

Product name:	Air Dryer	Reported date:	01.09.2023
Model No.	2KD030G	Visit date:	01.09.2023
Serial No.	2589-03/23	Call closed date:	01 .09 .2023
Call type: Chargeable			
Complaint type: Break Down		Call status:- Close	

for M/s GEM Equipments

for M/s Amaze air engineers

1. Mr. Amit Shukla

1.Mr.sanjay sharma

M/s Amaze air engineer reached the site on 01.08.2023 and during his visit the following inspections were carried out.

Dryer Model	SL No.	Issue Find out	Job carry out	Remark
GEM –AE40D	2589-03/23	Air Dryer not working	Air dryer not working properly. We have visit your plant and checked air dryer wiring properly than found one fuse damage, than our engineer installed the new fuse in the air dryer, than our engineer started the air dryer and he kept checking for a long time and the air dryer kept running in perfect condition	

1. M/s Amaze Engineer is leaving the site on 01.09.2023

For M/ S GEM Equipments (P) LTD

for M/s Amaze air engineers

Minutes of Meeting Between M/S Amaze air engineers and M/S SHRI Ram Rice Mills