



# RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,  
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337  
■ sales@riveramarketing.in ■ www.riveramarketing.in

Complaint - 4312

## SERVICE REPORT

Report No. 405

GST NO : 24AAFFR2824J1Z9

Date 10/01/2019

### Customer's Name & Address

Demic Chem Lab Limited  
457 village: chhatrai  
Gandhinagar

Ser. Engr's Name :

Jaysh Chavla

2018 NO :  
Machine Model :

2903259711

Serial No. :

3994-05/18

Contact Person Mr. Amit Shimpi

Hours Run :

Contact Number

Nature of Service :  Commissioning  Inspection  Repairs

Product Complaint / Failure

Water gas leakage is during time.  
I have attended the site check at the machine.  
Suction Pressure is ~~5~~ 5 PSI. I have fill up to 10 PSI.  
Gas Pressure to check leakage change pipe is leakage so  
I have to change point and another time fill nitrogen  
to NO any other leakage in Drier so I have vacuum the  
system and change the Water gas  
task the unit work good.

Spares Used Nitrogen, Oxygen, LPS  
Braking Acid, Water gas


Spares Recommended

Customer's Remarks : Your Mr. \_\_\_\_\_ Called on \_\_\_\_\_ He attended to  
the Job from \_\_\_\_\_ to \_\_\_\_\_ The Works in completed/not completed satisfactorily.

Service Engr. Jaysh Chavla  
993359953+

[Signature]  
Signature

Customer  
[Signature]  
Signature & Seal of the firm



GEM Equipments (P) Limited

