



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel, Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
✉ sales@riveramarketing.in 🌐 www.riveramarketing.in

Complaint No. 11442 DT-03-01-23

SERVICE REPORT

Report No. 179

GST NO : 24AAFFR2824J1Z9

Date 05/01/2023

Customer's Name & Address

Mulham Enterprise
Albida. (ONGC - RIG
185- M700 - II) Cuddalore
02.

Ser. Engr's Name :

Jayesh

Machine Model :

KRD 500

Serial No. :

11350

Contact Person

Mr Rajendra Patel

Contact Number

Hours Run :

Nature of Service : Commissioning Inspection Repairs

Product Complaint / Failure

Control failure / Ice formation in dryer

Work Done : I have visited the site check all the machine. The temperature controller is not show display because its failure so I have replace and change the new temperature controller and set the hot gas by pass valve and expansion valve. Now machine working good.

* Voltage = RY RB YB - Amps: R Y B
415 419 412 - 6 4.8 5.4

* Single phase - 238 volts AC.

Spares Used

Temperature Controller

(01 Nos)

Spares Recommended

Customer's Remarks : Your Mr. _____ Called on _____ He attended to the Job from _____ to _____ The Works in completed/not completed satisfactorily.

Service Engr.

Jayesh Chaudhary
Signature

Customer

Patel Rajendra M.
Signature & Seal of the firm
5-1-23

Authorised Dealers For :



GEM Equipments (P) Limited

