

MOM between M/s. Sanvira Industries Limited & M/s. GEM Equip Pvt Ltd at M/s. Sanvira Industries Limited Co-Gen Plant, Chattametta village, Rambili mandal, Visakhapatnam.

Attendees.:

M/s. Sanvira

M/s. Gem Equip

Mr. Ravikanth

Mr. Rajiv Gandhi

Mr. Santhosh Kumar

Sub.: Commissioning of Cooling Tower (CT-7) SCT800 --- Reg

Minutes.:

COMMISSIONING OF COOLING TOWER - 7



1. Mr. Rajiv Gandhi from M/s. GEM Equipments reached M/s. Sanvira site on 05.02.2019 to attend the above mentioned commissioning of cooling tower.
2. With the presence of M/S. GEM Equipments representative cooling tower (CT-7) was checked without water pressure. Then after checked by opening the water line and operation was observed for two hours. Found ok.
3. Absorbed Cooling tower operating at 21amps and temperature of Gearbox 48.3 degree celcius after two hours running of cooling tower fan.

OBSERVATION OF COOLING TOWER 3 & 4

1. Drift eliminators of both the Cooling tower 3 (CT-3) & Cooling tower 4 (CT-4) was checked by M/S. GEM Equipments representative and advised to replace the frame for the drift Eliminators. Sanvira told that the GI frame is corroding and ask M/s.Gem Equipments to give the alternate material which can work in the water atmosphere. M/s.Gem Equipments has to confirm.
2. M/s.Gem Equipments representative told to order ¼ th of the Fabricated drift eliminators for 4 Nos. of cooling towers which got damaged at present.
3. M/s.Gem Equipments and M/s.Sanvira together inspected the Cooling tower -3 and 4 and observed the FRP header got damaged. M/s.Gem Equipments has to analyse this type header failure and give the proper suggestions and modification sketch to M/s.Sanvira before 11.02.2019. M/s.Sanvira will adopt the same as per M/s.Gem Equipments suggestion.

M/s. Sanvira

M/s. Gem Equip


(C. Ravikanth)

(Mr. Santhosh Kumar)

