



# RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,  
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337  
■ sales@riveramarketing.in ● www.riveramarketing.in

## SERVICE REPORT

Report No. 32

GST NO : 24AAFFR2824J1Z9

Date 14-06-21

Customer's Name & Address

Quality Air Solutions  
A140, Chandra Prabha Society  
Near Chandra Prabha Phrederick

Ser. Engr's Name :

Jayesh

Machine Model :

2KD0156

Serial No. :

4255-08/20

Contact Person

Mr. Rajendra

Contact Number

Hours Run :

Nature of Service : ☐ Commissioning ☐ Inspection ☒ Repairs

☐ Product Complaint / Failure

Fan motor failure / Draw point High

Work Done : I have visited the site check at the machine. The Draw Point is High, because of fan motor is failure not working so I have change the new fan motor. Now machine working good.

Spares Used

Fan motor. OIL HO.

Spares Recommended

Customer's Remarks : Your Mr. \_\_\_\_\_

Called on \_\_\_\_\_

He attended to

the Job from \_\_\_\_\_

to \_\_\_\_\_

The Works in completed/not completed satisfactorily.

Service Engr.

Jayesh Chavla

Signature

Customer

Signature

Signature & Seal of the firm