



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel,
Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in ● www.riveramarketing.in

Complaint no. 4205

SERVICE REPORT

Report No. 383

GST NO : 24AAFFR2824J1Z9

Date 06/12/2018

Customer's Name & Address

Umichuron (Taitiki-sha - LTD)
GIDC Sarnand Ahmedabad

Ser. Engr's Name :

Jayesh Chaudhary

Machine Model :

KCRD-12751/ES

KCRD-12751/ES

Serial No. :

2235 - 03125

2236 - 03125

Contact Person Mr. Rajat Abujam

Contact Number

Hours Run :

Nature of Service : ☐ Commissioning ☐ Inspection ☐ Repairs

☐ Product Complaint / Failure

Work Done : AUTO drain valve check up moisture coming
filter is broken in side and pressure drop

101. S.L. : 2235 - 03125 : attended the site check at the machine
AUTO drain valve check-up I have clean the AUTO drain but
AUTO drain to moisture service pipe is check up - so I have
flushing the AIR so I have change the new PU pipe connection
machine works good.

102. S.L. : 2236 : Attended the site check at the machine.
AUTO drain valve is check-up so I have clean the AUTO drain
and flushing the pipe machine works good.

Spares Used pu pipe and 12" fitting
02 nos

Spares Recommended

no

Customer's Remarks : Your Mr. _____ Called on _____ He attended to
the Job from _____ to _____ The Works in completed/not completed satisfactorily.

Service Engr. Jayesh Chaudhary

Signature

Customer Kindly change the temporary PU pipe to
existing cu pipe. Dryer still under observation with
check with new filter installed Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.