

MoM between M/s. Chettinad Cement, Ariyalur Works [CPP] and
M/s. Gem Equipments, on 16.10.2019

Chettinad Cement

1. Mr. K. Girisan
2. Mr. V. Ramesh

Gem Equipments

1. Mr. Ganesan

Location: Captive Power Plant 3 & 4
Work Order No.: 257 dt: 29.06.2019

Subject: Supply, Dismantling, Erection and Commissioning of SCT 400LX2 Cooling tower – reg.

M/s. Gem Equipments arrived to site on 20.09.2019 for dismantling, erection and commissioning activities and completed the erection work on 04.10.19.

Commissioning of the Cooling tower completed on 05.10.19 and the cooling tower and fans are working satisfactorily. However, the performance of the cooling tower will be observed for a month and informed to M/s. Gem Equipments, if any deviation is observed.

Chettinad Cement

K. Girisan
(K. GIRISAN)

V. Ramesh
V. RAMESH

Gem Equipments

P. Ganesan
P. Ganesan

MoM between M/s. Chettinad Cement, Ariyalur Works [Cement Plant] and
M/s. Gem Equipments, on 15.10.2019

Chettinad Cement
1. Mr. P. Sivakumar
2. Mr. V. Ramesh

Gem Equipments
1. Mr. Ganesan

Location: Line-2 Cooling Tower
Work Order No.: 256 dt: 29.06.2019



Subject: Supply, Dismantling, Erection and Commissioning of SCT 600LX2 Cooling tower-reg.

M/s. Gem Equipments arrived to site on 03.09.19 for dismantling, erection and commissioning activities and completed the erection work on 19.09.19

Commissioning of the Cooling tower completed on 20.09.19 and the cooling tower and fans are working satisfactorily. However, the performance of the cooling tower will be observed for 10 days of running time and informed to M/s. Gem Equipments, if any deviation is observed.

Oil level switch glass tube was found broken on 09.10.19 and new one is replaced by M/s. Gem on 15.10.2019. It is under observation, any further crack/broken observed M/s. Gem has to replace immediately at free of cost, as it is under warranty.

Chettinad Cement

Gem Equipments

