

Job No - 077/01/2K19 HFCL Telangana



Dry Air Engineers

H. No. 01, Dawood Baug, Near Gole Hospital, Wireless Road,
 J. B. Nagar, Andheri (E), Mumbai - 400 059.
 Mob.: 9821825593 / 9321351867, Ph.: 022-65013989
 Email : binudae@rediffmail.com / dryairengineers@yahoo.com

Authorised Franchisee
GEM EQUIPMENTS (P) Ltd.



782

SERVICE REPORT

Sr. No.

Warranty / AMC / PER CALL		Complaint No.	
Customer: Kasco Industries Pvt Madapur Pune		Equipment: Cooling Tower	
Ph. No.: Fax No.:		Model: GCT-020L	
		Sr. No.: 3527-04/19	
Nature of Complaint: Erection for Cooling Tower with			
Analysis of Complaint:		Course of Defect:	
Action Taken: chocking and Assembling to The cooling Tower is his permission chocking material list and Assembl - Basin In-out Planch - Sinter Pipe - Fills coil - Spring W/len with pipe (fan motor is short)			
Spares list Short:		Observations:	
① motor - 0.5 HP = 1 no		(motor is short)	
② PVC End Coupl = 4 no		All cooling tower Assembl <u>OK</u>	
		Work Commenced Dt. 4-5-19 Time:	
		Work Completed Dt. 4-5-19 Time:	
General Instructions Customer:		Customer Remarks:	
① motor + PVC End clamp send immediately Tushar		Nameplate not fitted	
Service Engineer Name: Lokesh Shinde		Work attend to our Satisfaction.	
Signature: [Signature]		DATE	
Date: 4/5/19		KASCO INDUSTRIES PVT. LTD. STORE RECEIVED	
		Bharat Patil Customer's Name	
		[Signature] Signature	