



RIVERA MARKETING

206, Arihant Complex, Swastik Society, B/h. St. Xavier's Ladies Hostel, Navarangpura, Ahmedabad - 380 009 ☎ 079 - 26464337
■ sales@riveramarketing.in 🌐 www.riveramarketing.in

SERVICE REPORT

Report No. 65.

GST NO : 24AAFFR2824J1Z9

Date 10-07-2021.

Customer's Name & Address

Rama Gandhi Pvt Ltd.
Bhimadasi, Gandhidham.

Ser. Engr's Name :

Jyesh.

Machine Model :

2KD+100E

Serial No. :

12200-12179.

Contact Person

Mr. Rajesh Thakare.

Contact Number

Hours Run :

Nature of Service : Commissioning Inspection Repairs

Product Complaint / Failure

Dew point high / R407c gas leakage.

Work Done :

I have visited the site check at the machine. The dew point is high because of R407c gas is leakage in condenser side. So I have brazing the system and fill up to nitrogen gas pressure 300psi to check leakage in days. No any other leakage in days. So I have vacuum the system and recharge the R407c gas. (6 kg).

Voltage - RV1 RB YB Amps: R Y B
12.5 14.1 12.1
407 406 403 Dew Point: 6.0°C

Air inlet Temp: 35°C

Spares Used

R407c gas, Nitrogen, L.P.O. Oxygen, Brazing Rod.

Spares Recommended

Customer's Remarks : Your Mr. Jyesh.

Called on _____

He attended to

the Job from _____

to _____

The Works in completed/not completed satisfactorily.

Service Engr.

Jyesh Chakr.
Jsh.
Signature

Customer

[Signature]
Signature & Seal of the firm

Authorised Dealers For :



GEM Equipments (P) Limited



Fine Filters Pvt Ltd.